



**Kent  
Police**

**CD3.08**

**Protecting and serving the people of Kent**

Planning Officer  
Canterbury City Council  
Planning & Regeneration Services  
Council offices  
Military Road  
Canterbury  
Kent CT1 1YW

Direct Line: 01622 653209  
E-mail: emily.hook@kent.police.uk  
Date: 5<sup>th</sup> May 2023  
Ref: CA/23/00484/EH1.324

**Location:** Land At The Hill Bokesbourne Lane East Of Bokesbourne Hill Bokesbourne  
Canterbury CT4 5EA  
**Proposal:** Outline planning application for up to 300 residential dwellings (including affordable housing and older person accommodation), a new community hub, introduction of structural planting and landscaping, informal public open space and children's play area and surface water flood mitigation and attenuation. All matters reserved except for access.

We have reviewed this application in regard to Crime Prevention Through Environmental Design (CPTED) and in accordance with the National Planning Policy Framework (NPPF).

Applicants/agents should consult us as Designing out Crime Officers (DOCO's) to address CPTED and incorporate Secured By Design (SBD) as appropriate. We use details of the site, relevant crime levels/type and intelligence information to help design out the opportunity for Crime, Fear of Crime, Anti-Social Behaviour (ASB), Nuisance and Conflict.

There is a carbon cost for crime and new developments give an opportunity to address it. Using CPTED along with attaining an SBD award using SBD guidance, policies and academic research would be evidence of the applicants' efforts to design out the opportunity for crime.

We request a condition for this site to follow SBD Homes 2019 guidance to address designing out crime to show a clear audit trail for Designing Out Crime, Crime Prevention and Community Safety and to meet our Local Authority statutory duties under Section 17 of the Crime and Disorder Act 1998.

1. Consideration should be given to the provision of informal association spaces for members of the community, particularly young people. These must be subject to surveillance but sited so that residents will not suffer from possible noise pollution, in particular the green spaces surrounding the site and the any parking areas. These areas must be well lit and covered by natural surveillance from neighbouring properties.
2. Perimeter, boundary and divisional treatments must be a minimum of 1.8m high. Any alleyways must have secure side gates, which are lockable from both sides, located flush to the front building line.
3. We would strongly recommend the installation of pavements on both sides of the roads to avoid vehicle and pedestrian conflict, as opposed to shared surfaces. If shared surfaces are used within this design, we recommend traffic calming measures for pedestrian safety.
4. To help address vehicle crime, security should be provided for Motorbikes, Mopeds, Electric bikes and similar. SBD or sold secure ground or wall anchors can help provide this. We advise against the use of parking courts as they can create an opportunity for crime. Where unavoidable, the areas must be covered by natural surveillance from an "active" window e.g. lounge or kitchen and sufficient lighting – the same recommendations apply to

- on plot parking bays. In addition, we request appropriate signage for visitor bays to avoid conflict and misuse.
5. New trees should help protect and enhance security without reducing the opportunity for surveillance or the effectiveness of lighting. Tall slender trees with a crown of above 2m rather than low crowned species are more suitable than "round shaped" trees with a low crown. New trees should not be planted within parking areas or too close to street lighting. Any hedges should be no higher than 1m, so that they do not obscure vulnerable areas.
  6. Lighting. Please note, whilst we are not qualified lighting engineers, any lighting plan should be approved by a professional lighting engineer (e.g. a Member of the ILP), particularly where a lighting condition is imposed, to help avoid conflict and light pollution. Bollard lighting should be avoided, SBD Homes 2019 states: "18.3 Bollard lighting is purely for wayfinding and can be easily obscured. It does not project sufficient light at the right height making it difficult to recognise facial features and as a result causes an increase in the fear of crime. It should be avoided." Lighting of all roads including main, side roads, cul de sacs and car parking areas should be to BS5489-1:2020 in accordance with SBD and the British Parking Association (BPA) Park Mark Safer Parking Scheme specifications and standards.
  7. Play areas must have a self-closing gate to keep animals out and ensure young children cannot leave the area unsupervised. Play equipment must be vandal resistant (and if made of wood, fire resistant) and not provide areas of concealment or an informal storage area for offenders or materials of crime. We recommend the sales team advise potential buyers of the plots close to the play area of it's location, which would otherwise be missed from the plan. By informing them at this stage, this reduces the possibility of future conflict and/or noise complaints.
  8. All external doorsets (a doorset is the door, fabrication, hinges, frame, installation and locks) including folding, sliding or patio doors to meet PAS 24: 2016 UKAS certified standard, STS 201 or LPS 2081 Security Rating B+. Please Note, PAS 24: 2012 tested for ADQ (Building Regs) has been superseded and is not suitable for this development.
  9. Windows on the ground floor or potentially vulnerable e.g. from flat roofs or balconies to meet PAS 24: 2016 UKAS certified standard, STS 204 Issue 6:2016, LPS 1175 Issue 8:2018 Security Rating 1/A1, STS 202 Issue 7:2016 Burglary Rating 1 or LPS 2081 Issue 1.1:2016 Security Rating A. Glazing to be laminated. Toughened glass alone is not suitable for security purposes.
  10. We advise on the use of ground/ wall SBD or sold secure anchors within the cycle storage area and sheds of dwellings.

If approved, site security is required for the construction phase. There is a duty for the principle contractor "to take reasonable steps to prevent access by unauthorised persons to the construction site" under the Construction (Design and Management) Regulations 2007. The site security should incorporate plant, machinery, supplies, tools and other vehicles and be site specific to geography and site requirements.

We welcome a discussion with the applicant/agent about site specific designing out crime. If the points above are not addressed, they can affect the development and local policing.

This information is provided by Kent Police DOCO's and refers to situational crime prevention. This advice focuses on CPTED and Community Safety with regard to this specific planning application.

Yours sincerely

**DOCO.**

Designing Out Crime Officer  
Public Protection and Partnerships Command  
PVP Central Co-ordination Department